

Surfaces appear to be cleaned and decontaminated after work is performed (no chemical residue, dust, biohazards, etc.). General work space, storage areas, and					

First aid medication/antidotes are available and within expiration dates. (i.e. calcium gluconate for HF exposure).					
Access to electrical breaker panels and emergency shutoff controls is unobstructed with 3' clearance. Registration is current & emergency contact numbers/location details are posted.					

Ladders are labeled with the approved warning stickers and are inspected before each use.					
Radiation Producing Equipment is registered with SRM and NC Radiation Protection Section.					